



Government of West Bengal  
Office of the Divisional Fire Officer  
West Bengal Fire & Emergency Services  
Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134

Memo No.: FSR/IND/WB/FES/20192020/82110

Date : 12-06-2024

From :  
Divisional Fire Officer  
South Dinajpur Division,  
West Bengal Fire & Emergency Services

To :  
ATREYEE DAV PUBLIC SCHOOL  
VILL-MANGALPUR, P.O-BALURGHAT, P.S-BALURGHAT, DIST- DAKSHIN DINAJPUR, JL.NO-107, PLOT NO-  
512,513,514,, KH.NO-1246,1230, UNDER MOUZA-MANGALPUR

Sub : Issuance of Renewal Fire Safety Certificate for Existing construction of G+2 storied Building under group of Educational in the name of premises- ATREYEE DAV PUBLIC SCHOOL ,VILL-MANGALPUR, P.O+ P.S- BALURGHAT, DIST-DAKSHIN DINAJPUR, PIN-733121,JL.NO-107, PLOT NO-512,516,514, KH.NO-1246 & 1230, UNDER MOUZA-MANGALPUR..

This is in reference to your AIN 211912406300000794 dated 05-Jun-2024 regarding Issuance of Renewal Fire Safety Certificate for Existing construction of G+2 storied Building under group of Educational in the name of premises- ATREYEE DAV PUBLIC SCHOOL ,VILL-MANGALPUR, P.O+ P.S-BALURGHAT, DIST-DAKSHIN DINAJPUR, PIN- 733121,JL.NO-107, PLOT NO-512,516,514, KH.NO-1246 & 1230, UNDER MOUZA-MANGALPUR..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000794

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
3. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building( ATREYEE DAV PUBLIC SCHOOL) shall be strictly maintained.
4. Existing Electrical wiring of the whole building (ATREYEE DAV PUBLIC SCHOOL) shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and evacuation from the building(ATREYEE DAV PUBLIC SCHOOL) shall be prepared and displayed at all vulnerable of the building.
6. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
7. A Crew of trained fire man should be maintained round the clock for the safety of the building.
8. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
9. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
13. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
14. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629\_L Dated-17/04/2018.
15. After three years a certificate is to be obtained from the Divisional fire officer, West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Memo No.:

FSR/IND/WB/FES/20192020/82110

Valid Upto : 11-Jun-2027



Signature valid

Digitally Signed.  
Name: SHIBA NANDA BARMAN  
Date: 12-Jun-2022 17:58:59  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000794



## FIRE SAFETY CERTIFICATE

No.

Dated:

Certified that the **Atreyee DAV Public School** (name of the building or premises) at **Mongalpur, Balurghat, Dist. Dakshin Dinajpur, Pin: 733101, W.B.** (address) comprised of **3 (three)** basement(s) and **5 (five)** (upper floors) owned/ occupied by **Atreyee DAV Public School** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on .....11-6-2024 (date of inspection) in the presence of **Principal, Atreyee DAV Public School** (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes **DCPI Co2 (X/XII)** With effect from 12-06-2024 for a period of **3 (Three)** years in accordance with rule and subject to compliance of specific conditions.

*Renewal Fire Safety Certificate*

Issued on 12-06-24 at 12 noon (date of issue) at Dakshin Dinajpur (place) by

*vide Memo No. FSR/IND/NB/FES/2019-20/82110 dt. 12-6-2024  
& AIN NO. 2119124063 00060794 dt. 5-6-2024*

\*Strike out which ever is not applicable.

Signature with Seal: .....

Name

*SHIBA NANDA BARMAN*

Designation

*Divisional Fire Officer*

Name &amp; Address of Department/Office:

**Divisional Fire Officer  
Dakshin Dinajpur Division  
West Bengal Fire & Emergency Services**

To

**Atreyee DAV Public School  
Mongalpur, Balurghat,  
Dist. Dakshin Dinajpur, W.B.**

(Name & Address of the Institution)

## ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

\*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.