



Government Of West Bengal  
Office Of The Divisional Fire Officer, South Dinajpur  
West Bengal Fire & Emergency Services  
Raiganj Fire Station, College Para, P.O :- Raiganj, Pin :- 733134

Memorandum No. IND/WB/FES/20192020/82110

Date: 14-12-2020

From: The Fire Officer, South Dinajpur  
West Bengal Fire & Emergency Services

To: ATREYEE DAV PUBLIC SCHOOL

Vill-Mongalpur, P.o-Balurghat, P.s-Balurghat, Dist- Dakshin Dinajpur, Pin-733101, J.L NO-107, PLOT NO-512, 513, 514, K.H.NO-1246 & 1230, Under mouza-Mongalpur

For the issuance of Fire Safety Certificate for an existing construction of G+2 storied building under group of Educational at the premises no- ATREYEE DAV PUBLIC SCHOOL, VILL- MONGALPUR, P.O-BALURGHAT, P.S-BALURGHAT, DIST-DAKSHIN DINAJPUR, PIN-733101, J.L NO-107, PLOT NO-512, 513, 514, K.H NO-1246 & 1230, Under Mouza- Mongalpur.

In response to your application no. 012618920070/030 dated 31/11/2020 regarding the issuance of Fire Safety Certificate for existing construction of G+2 storied building under group of Educational at the premises no- ATREYEE DAV PUBLIC SCHOOL, VILL- MONGALPUR, P.O-BALURGHAT, P.S-BALURGHAT, DIST-DAKSHIN DINAJPUR, PIN-733101, J.L NO-107, PLOT NO-512, 513, 514, K.H NO-1246 & 1230, Under Mouza- Mongalpur

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found to be in working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the building.

Recommendation:

In order to bring up the Fire Safety Measures of the aforesaid building, the following safety measures need to be taken:

1. Fire pump of adequate capacity shall have to be installed
2. Fresh decoration of the building shall be made with low flame spread materials conforming to the I.S.
3. Measures of fire hazards, good house keeping both for inside and outside building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them. If require old electrical lines shall be replaced with new electrical lines. Cables shall always be laid in M.S conduit pipes and grounded to the earth.
5. Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.

ATTESTED

*[Signature]*  
Principal

*[Signature]*

Employee and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate same. Fire and Testing.

Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

Fire fighting system shall be provided as per I.S. Specifications.

Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all times.


Validity certificate is valid for Three years and has to be renewed after three years from the date of issue of this certificate. Govt. of West Bengal Vide Notification No- 629 / I. Dated-17/04/2018

Signature valid



Divisional Fire Officer, South Division  
West Bengal Fire & Emergency Services

ATTESTED



Principal

Atreyee D.A.V. Public School  
Barrabazar, Barrabazar, Pin-733101  
Dist- Brahmbari Dinapur, (W.B)



MANAGER

ATREYEE D.A.V. PUBLIC SCHOOL  
Barrabazar, Barrabazar, W.B