



APPENDIX-VIII

PROFROMA REGARDING HEALTH, SANITARY CONDITION AND SAFE DRINKING WATER CERTIFICATE

Memo No.168/DGP

Date-17/02/2025

It is certified that an inspection team headed by Aporna Barman (Name of Officers with designation) from Prodhan 6 No. Danga Gram Panchayat (Name of Department/Office) inspected the sanitary condition in & around the school campus of the Areyee DAV Public School, Mongalpur, Balurghat. Dist-Dakshin Dinajpur. W.B (Name & Address of the School) on 17/02/2025 and found that the Areyee DAV Public School, Mongalpur, Balurghat, Dist-Dakshin Dinajpur, W.B. (Name of the School) is maintaining the Health, Drinking Water and Sanitary Condition in the school building & the campus as per the norms prescribed by the Central/State /U.T.Govt.

The above certificate is valid for a period 3 (three years upto February-2028).



Aporna Barman
Signature with Seal
No.6 Danga G.P.
Balurghat Block, D/Dinajpur
Name: *Aporna Barman*

Designation : *Prodhan*
No.6, Danga G.P.
Balurghat Block.
P.O. B.T. Park
Dist - D Dinajpur
(WB)

To
The Principal
Areyee DAV Public School,
Mongalpur, Balurghat, Dist-Dakshin Dinajpur, W.B
(Name & Address of the Institution)

R.K.M. 17/02/25
Secretary
No.6 DANGA G.P.
Balurghat Block, D/Dinajpur

S. Sarkar
Headmaster
Areyee D.A.V. Public School
Mongalpur, Balurghat, D/Dinajpur

Nirmala Sahayak
No.6 DANGA G.P.
Balurghat Block, D/Dinajpur

Smt. S.
Manager
Areyee D.A.V. Public School
Mongalpur, Balurghat, D/Dinajpur



GOVERNMENT OF WEST BENGAL
DAKSHIN DINAJPUR DISTRICT WATER TESTING
LABORATORY
UNDER OFFICE OF THE ASSISTANT ENGINEER, RWS
BALURGHAT SUB - DIVISION: P.H.ENGINEERING DIRECTORATE
RAGHUNATH PUR, P.H.E.COMPLEX, BALURGHAT, DAKSHIN DINAJPUR.

A. Report No :- February/02/2025

B. Name of Applicant :- Headmaster (Sandip Sarkar) ,Atreyee D.A.V Public School , Balurghat, Dakshin. Dinajpur .

C. Date of receiving of samples :- 11/02/2025

Sample Collected /Submitted by :- School Staff

F. From which water samples collected :- Type of Source (Aquagurad Water) , Atreyee D.A.V Public School ,
Near- Mongalpur , Balurghat , Dakshin Dinajpur

E. Type of sample container :- Polypropylene Container & Sterilized glass container.


Date of testing :-12/02/2025


The Sample(S) of water from above source(s) has been caused to be chemically examined and findings are as follows:-

Sl No	Substance of Characteristic	Experimental Result Tested	Desirable Limit	Permissible Limit	Remarks
			As per IS 10500 (2012)		
1	pH	6.82	6.5 to 8.5	No relaxation	Within limit.
2	Iron mg/L.	0.61	0.3	1.0	Within limit.
3	Total Hardness (as CaCO ₃) mg/L.	168	200	600	Below desirable limit .
4	TDS mg/L.	162	500	2000	Below desirable limit .
5	Turbidity NTU	1.03	1	5	Within limit.
6	Fluoride mg/L.	0.24	1	1.5	Below desirable limit .
7	Manganese mg/L.	0.05	0.1	0.3	Below desirable limit .


The Sample(S) of water from above source(s) has been caused to be Bacteriological examined and findings are as follows:-

Sl No.	Tested Parameter	Test Result	Observation	Permissible Limit as per IS 10500 :2012
1.	Presumptive Test (Total Coliform Test) CFU/100 ml	0	No T.C has been detected.	Shall not be detectable in any 100 ml sample
2.	Confirmatory test for Faecal Coliform CFU/100 ml	0	No E .Coli has been detected.	Shall not be detectable in any 100 ml sample


Signature of Chemist
D/ Dinajpur Dist.Lab.
PHED


Signature of D.C
D/Dinajpur
PHED


Headmaster
Atreyee D.A.V. Public School
Mongalpur, Balurghat, D/Dinajpur


Signature of J.E
Lab - In - Charge
Balurghat Division PHED